



# OAR 340-053-0090

## Table 2

<b>OAR 340-053-0090</b>				
<b>Table 2</b>				
<b>Minimum Horizontal Separation Distances (in feet)</b>				
<b>Feature requiring setback</b>	<b>Graywater storage or surge tank</b>	<b>Point of graywater discharge to landscape for irrigation or edge of landscape pond</b>		
		<b>Type 1</b>	<b>Type 2</b>	<b>Type 3</b>
Groundwater supplies and wells	50	100	50	50
Springs	50	100	50	50
Surface waters of the state, excluding springs	50	50	25	25
Stormwater management structures, collection systems, and catch basins	10	10	10	10
Underground Injection Control Systems (UICs)	10	10	10	10
Property boundaries	5	2	2	*
Building structures	0	0	0	*

\* Where sprinkler irrigation is used, there must be 10 feet from the edge of the site used for irrigation and the property boundary and graywater must not be sprayed within 10 feet of an area where food is being prepared or served, or where a drinking fountain is located.