



State of Oregon Department of Environmental Quality

# OAR 340-150-0352 Appendix H

## APPENDIX H

### 340-150-0350 UST System Repairs

The following codes and standards may be used to comply with these rules:

- (1) National Fire Protection Association Standard 326, “Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning or Repair”;
- (2) American Petroleum Institute Recommended Practice 1631, “Interior Lining and Periodic Inspection of Underground Storage Tanks”;
- (3) National Association of Corrosion Engineers Standard RP-0285, “Corrosion Control of Underground Storage Tank Systems by Cathodic Protection”;
- (4) American Petroleum Institute Recommended Practice 1632, “Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems”;
- (5) Ken Wilcox Associates, “Recommended Practice for Inspecting Buried Lined Steel Tanks Using a Video Camera”;
- (6) National Association of Corrosion Engineers Standard SP0178, “Design, Fabrication, and Surface Finish Practices for Tanks and Vessels to be lined for Immersion Service”;
- (7) American Society of Testing and Materials G 158, “Standard Guide for Three Methods of Assessing Buried Steel Tanks”; and
- (8) American Society of Testing and Materials E 1990, “Standard Guide for Performing Evaluations of Underground Storage Tank Systems for Operational Compliance with 40 CFR, Part 280 Regulations.”