

§9.140. Uniform Protection Standards

Table 1 (Revised February 2008)

Requirements	Self-service Dispenser Area	Storage Racks for DOT Portable or Forklift Containers	Licensee or Non- Licensee ASME 4001+ Gal. A.W.C.	Any Licensee Installation (DOT Container Filling and/or Service Station Only)
1. Red letters at least 2" high (or at least 1 1/4" high for storage racks for DOT portable or forklift cylinders) on white or aluminum background: NO SMOKING	*	*	*	*
2. Red letters at least 4" high on white or aluminum background: WARNING FLAMMABLE GAS			*	
3. Black letters at least 4" high: NO TRESPASSING AUTHORIZED PERSONNEL ONLY			*	
4. Letters at least 1/2" high: EXTINGUISH ALL PILOT LIGHTS AND OPEN FLAMES; VEHICLE MUST BE VACATED DURING FILLING PROCESS; TURN OFF ENGINE	*			*
5. Letters at least 2" high on each operating side of the dispenser: PROPANE	*			
6. Block letters at least 2" high on a background of contrasting color to the letters, including instructions on activation and visible from the point of transfer: PROPANE (or LP-GAS) EMERGENCY SHUTOFF	*		*	*
7. Letters at least 4" high on container or 1 1/4" high on cylinder exchange or storage rack indicating contents: LP-GAS or BUTANE or PROPANE and FLAMMABLE		*	*	*
8. Letters at least 4" high on a background of contrasting color to the letters, marked on both sides or both ends of any container holding unodorized gas: NOT ODORIZED			*	*
9. Letters at least 4" high: Name of Licensee (not required for nonlicensee installations)			*	*
10. Letters at least 2" high on operating end of container: W.P. _____, WORKING PRESSURE _____, or WORK PRESS. _____			*	*
11. If more than one container, letters at least 2" high on operating end of each container: CONTAINER NO. _____ or TANK NO. _____			*	*

12. Letters at least 2" high on a background of contrasting color, readily visible to the public, stating: 24-Hour Emergency Number _____ (not required at non-licensee installations)	*	*	*	*
13. Lettering at least 3/4" high with the telephone number of the certified employee responsible for the outlet, and/or the operations supervisor, on a background of contrasting color, readily visible to the public (not required at nonlicensee installations)	*		*	*