

Figure: 16 TAC §9.313

<b>NFPA 54 Sections with Additional Requirements or Not Adopted (Effective September 1, 2020)</b>		
<b>Affected NFPA 54 Section</b>	<b>Specific Action</b>	<b>Commission Rule(s) to be Followed or Other Comments</b>
Chapter 7	additional requirements	See Commission rule '9.308, Identification of Piping Installation
9.1.3	additional requirements	See Commission rule '9.307, Identification of Converted Appliances.
9.6.2	additional requirements	See Commission rule '9.311(a), Special Exceptions for Agricultural and Industrial Structures Regarding Appliance Connectors and Piping Support.
10.22.3	additional requirements	See Commission rule '9.306, Room Heaters in Public Buildings.
10.28	not adopted	See Commission rule '9.303, Exclusion of NFPA 54, §10.28