

Figure: 16 TAC §14.2803

<b>NFPA 52 Sections with Additional Requirements or Not Adopted</b>		
<b>Affected NFPA 52 Section</b>	<b>Specific Action</b>	<b>Commission Rule(s) to be Followed or Other Comments</b>
1.4.3	additional requirement	See Commission rule §14.2025, Designation and Responsibilities of Company Representatives and Operations Supervisors
4.1	additional requirement	See Commission rule §14.2019, Examination Requirements and Renewals
4.2	additional requirement	See Commission rule §14.2019, Examination Requirements and Renewals and §14.2025, Designation and Responsibilities of Company Representatives and Operations Supervisors
4.3	additional requirement	See Commission rule §14.2052, Application for an Exception to a Safety Rule
Chapter 5	not adopted	NFPA 52 Chapter 5 does not apply to LNG installations
Chapter 6	not adopted	NFPA 52 Chapter 6 does not apply to LNG installations
Chapter 7	not adopted	NFPA 52 Chapter 7 does not apply to LNG installations
Chapter 8	not adopted	NFPA 52 Chapter 8 does not apply to LNG installations
9.12.1.2	additional requirement	See Commission rule §14.2610, Installation of Vehicle Fuel Containers
10.4.1	additional requirement	See Commission rule §14.2319, Automatic Fuel Dispenser Safety Requirements
13.5	additional requirement	See Commission rule §14.2110, LNG Container Installation Distance Requirements
Chapter 14	not adopted	Commission rules in Chapter 14 do not cover marine installations