

FORM NO. 2-C**APPENDIX C - CERTIFICATION REQUIREMENTS**

1. Small Generating Facility equipment proposed for use separately or packaged with other equipment in an interconnection system shall be considered certified for interconnected operation if (1) it has been tested in accordance with IEEE 1547.1 in compliance with the appropriate codes and standards referenced below in Appendix G by any Nationally Recognized Testing Laboratory (NRTL) recognized by the United States Occupational Safety and Health Administration to test and certify interconnection equipment pursuant to the relevant codes and standards listed in Appendix G, (2) it has been labeled and is publicly listed by such NRTL at the time of the interconnection application, and (3) such NRTL makes readily available for verification all test standards and procedures it utilized in performing such equipment certification, and, with consumer approval, the test data itself. The NRTL may make such information available on its web site and by encouraging such information to be included in the manufacturer's literature accompanying the equipment.
2. The Interconnection Customer must verify that the intended use of the Interconnection Equipment falls within the use or uses for which the Interconnection Equipment was labeled, and listed by the NRTL.
3. Certified Interconnection Equipment shall not require further type-test review, testing, or additional equipment to meet the requirements of this Standard Small Generator Interconnection Procedure; however, nothing herein shall preclude the need for an on-site Witness Test nor follow-up production testing by the Interconnection Customer.
4. If the Certified Interconnection Equipment package includes only interface components (switchgear, inverters, or other interface devices), then an Interconnection Customer must show that the generator or other electric source being utilized with the equipment package is compatible with the equipment package and is consistent with the testing and listing specified for this type of interconnection equipment.
5. Provided the generator or electric source, when combined with the equipment package, is within the range of capabilities for which it was tested by the NRTL, and does not violate the interface components' labeling and listing performed by the NRTL, no further design review, testing or additional equipment on the customer side of the point of common coupling shall be required to meet the requirements of this interconnection procedure.
6. Interconnection Equipment does not include equipment provided by the Utility.