



**Department
of Commerce**

Division of State Fire Marshal
John R. Kasich, Governor
Jacqueline T. Williams, Director

ENACTED
Appendix
1301:7-7-01

DATE: 12/26/2018 8:54 AM

Type A Child Care Facility Inspection

<u>Owner/Administrator Name</u>				
<u>Address</u>				
<u>City</u>		<u>State</u>		<u>Zip</u>

Inspection Checklist

<u>Storage is neat and orderly</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>A fire safety and evacuation plan is prepared and maintained on site</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Fire drills are being performed and records are being kept for review</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Address numbers are in a location that is plainly legible and visible from the street/road</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Storage is separated from heaters or heating devices</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Portable unvented heaters are not being used</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Multiplug adapters are not being used</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Extension cords are not being used in place of permanent wiring</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Approved covers are provided for all switch and electrical outlet boxes</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Open wiring splices are not present</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>"Seating furniture" complies with flammability standards</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Interior wall and ceiling finish and trim complies with flammability standards</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>The single- or multiple-station smoke alarms are operable</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>The single- or multiple-station smoke alarms are clearly audible and able to warn all occupants within all areas</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>On each floor where child care is provided, a 2-A:10-B:C or larger portable fire extinguisher is conspicuously located within the path of egress travel</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>If the home is not equipped with an automatic sprinkler system, each floor used for child care has at least two means of egress (one of the means of egress may be an emergency escape and rescue opening in accordance with the Ohio Residential Code)</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>If the home is not equipped with an automatic sprinkler system, the grade level floor is connected to the other floors where child care is provided by means of an interior stairway providing a continuous enclosure resistant to the passage of smoke or an exterior stairway protected to prevent the accumulation of ice and snow</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>All children under three years of age and all non-ambulatory children receive care on a floor with an exterior grade level access/exiting door</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>Where two exiting means are provided, they are as remote as practicable so as to minimize the possibility that both may be blocked by fire or other emergency</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
<u>All exiting means are located such that the maximum distance from the most remote point on any given floor along a natural unobstructed path of travel does not exceed 100 feet</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA

If egress from a room or space is through an adjoining or intervening room or area, that adjoining or intervening room or area is of lesser hazard than the room or space from which egress is made. A direct exiting means is provided	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
If a means of exiting passes through a kitchen, storeroom, restroom, closet or similar space, another means of exiting is provided	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
All egress doors are readily openable from the side from which egress is to be made without the use of a key, special effort or knowledge	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
All door latching devices on closets located in child care areas can be opened by children from the inside	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
If bathroom door locking hardware is used, the door can be unlocked from outside the bathroom. The unlocking device or key is readily accessible to staff	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
All means of egress are being maintained unobstructed	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
The floor surfaces of the means of egress are provided with illumination, including angles and intersections of corridors, passageways, stairway landings and exit doors	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA
The illumination is arranged so that a failure of any single lighting unit, such as the burning out of an electric light, will not leave any area in darkness	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA

Inspection Date		<input type="checkbox"/> Pass	<input type="checkbox"/> Fail
<u>Pass/Fail indication is limited to the content of this form and does not otherwise reflect compliance with any other applicable provision of the Ohio Fire Code or any other licensure requirements.</u>			
Inspection Completed By		Fire Department	