



Department of Commerce

Division of State Fire Marshal
8895 East Main Street, Reynoldsburg, Ohio 43068
614.728.5460 Fax 614.728-5168
Email sfm\_codeenf@com.state.oh.us

EXISTING
Appendix
1301:7-7-56

Checklist for Indoor Fireworks or Flame Effects Exhibition

DATE: 03/20/2023 8:35 AM

Permit # \_\_\_\_\_

Location of Event
City & County of Exhibition
Date & Time of Exhibition
FD Name
Exhibitor's Name
Exhibitors License Number
Exhibitor's Phone Number

Initialing each step indicates the step has been completed

Fire Official Exhibitor

Table with 22 rows of questions and 2 columns for Fire Official and Exhibitor initials.

By signing this form below, I acknowledge that I understand and have followed all the requirements and procedures described in this checklist. To the best of my knowledge, the information included in this document is complete and accurate. Procedures described herein have been followed by myself and all the other properly authorized participants in this exhibition of fireworks.

Fire Chief/Fire Prevention Officer: \_\_\_\_\_ Date: \_\_\_\_\_

Ohio Licensed Exhibitor: \_\_\_\_\_ Date: \_\_\_\_\_

Provide completed copy of form to the following: Exhibitor, Fire Chief/Fire Prevention Officer, Law Enforcement Officer and State Fire Marshal

## Code References

1. In accordance with division (D) of Section 3743.54 of the Revised Code.
2. In accordance with division (A) of Section 3743.54 of the Revised Code.
3. In accordance with paragraph (K)(2)(e)(5611.2.5) and (L)(2)(e)(5612.2.5) of this rule.
4. In accordance with division (C) of Section 3743.54 of the Revised Code.
5. In accordance with NFPA 1126 Section 6.1.4 as listed in rule 1301:7-7-80 of the Administrative Code.
6. In accordance with NFPA 160 Section 5.3.1 and NFPA 1126 Section 6.3.2 as listed in rule 1301:7-7-80 of the Administrative Code.
7. In accordance with NFPA 160 Section 5.3.1.2 and NFPA 1126 Section 6.1 as listed in rule 1301:7-7-80 of the Administrative Code.
8. In accordance with NFPA 160 Section 7.10 and NFPA 1126 Section 6.3.2 as listed in rule 1301:7-7-80 of the Administrative Code.
9. In accordance with NFPA 160 Section 5.4 and NFPA 1126 Section 6.4.1.1 as listed in rule 1301:7-7-80 of the Administrative Code.
10. In accordance with NFPA 160 Section 5.3.1.2 and NFPA 1126 Section 6.3.2 as listed in rule 1301:7-7-80 of the Administrative Code.
11. In accordance with NFPA 160 Section 6.1 as listed in rule 1301:7-7-80 of the Administrative Code.
12. In accordance with NFPA 160 Section 9.3 as listed in rule 1301:7-7-80 of the Administrative Code.
13. In accordance with NFPA 1126 Section 9.1.1 as listed in rule 1301:7-7-80 of the Administrative Code.
14. In accordance with NFPA 160 Section 5.5 and NFPA 1126 Section 6.4.3 as listed in rule 1301:7-7-80 of the Administrative Code.
15. In accordance with NFPA 160 Section 11.3.2 and NFPA 1126 Section 8.1 as listed in rule 1301:7-7-80 of the Administrative Code.
16. In accordance with NFPA 1126 Section 7.2 as listed in rule 1301:7-7-80 of the Administrative Code.
17. In accordance with NFPA 1126 Section 8.3.5 as listed in rule 1301:7-7-80 of the Administrative Code.
18. In accordance with NFPA 160 Section 4.2.2 and NFPA 1126 Section 5.2.3 as listed in rule 1301:7-7-80 of the Administrative Code.
19. In accordance with NFPA 1126 Section 8.2 as listed in rule 1301:7-7-80 of the Administrative Code.
20. In accordance with NFPA 160 Section 7.4 and NFPA 1126 Section 8.5.5 as listed in rule 1301:7-7-80 of the Administrative Code.
21. In accordance with NFPA 1126 Section 8.2.5 as listed in rule 1301:7-7-80 of the Administrative Code.
22. In accordance with NFPA 1126 Section 6.1.3 as listed in rule 1301:7-7-80 of the Administrative Code.

NFPA 160-2011 Edition  
NFPA 1126-2011 Edition

## Additional Requirements

- Both the fire official and licensed exhibitor should mutually agree in advance on a method used to communicate during the exhibition. Agreement should also be made in advance pertaining to the exact location the fire official will be stationed to maintain safety for all involved.
- If a condition arises requiring the entry of fire protection or other emergency response personnel into the fallout area security perimeter, the display shall be halted until the situation is resolved.
- If a significant hazard exists due to weather, lack of crowd control, or other condition, the exhibition shall be halted until resolved.
- The security of the display site shall be maintained until released by the exhibitor.
- Check with the safety person and monitors for any signs of problems.
- Allow registered assistants to enter the area and attend to extinguishing fires, smoldering embers and debris in the fire area and fallout area.
- Before entering the area, wait a minimum period of time that the exhibitor deems necessary, to include letting the area cool with resulting inspection by fireworks crew.
- Confer with the licensed exhibitor and, if mutually agreed, release fire crew and equipment from the scene. Do not release security or monitors. Maintain barricades for area until spectators have left.
- Be sure all live product and duds are properly repackaged and secured into the vehicle. Replace placards on vehicle.
- Appropriate reinspection of the site should be mutually agreed to.

The completed permit application and completed checklist constitute final approval by the AHJ. These forms shall be submitted to the State Fire Marshal's office by the fire official no later than **five** days after the date of exhibition. Please return to:

**Division of State Fire Marshal**  
**Code Enforcement**  
**8895 East Main Street**  
**Reynoldsburg, Ohio 43068**  
[sfm\\_codeenf@com.state.oh.us](mailto:sfm_codeenf@com.state.oh.us)

This checklist is not a substitute to reviewing and complying with Chapter 3743. of the Revised Code, Ohio Fire Code 1301:7-7-56, NFPA 1126 and NFPA 160 as listed in rule 1301:7-7-80 of the Administrative Code as it relates to Fireworks Exhibitions.

**TO REPORT AN INCIDENT CALL 800.589.2728 OR 614.752.7106**