

**OREGON ADMINISTRATIVE RULES
WATER RESOURCES DEPARTMENT
CHAPTER 690, DIVISION 210
WELL CONSTRUCTION STANDARDS**

TABLE 210-2

(Minimum specifications for steel well casing)

Nominal Size (inches)	Outside Diameter (inches)	Wall Thickness (inches)	Weight Per Foot (pounds)
2	2.375	.154	3.65
2-1/2	2.875	.203	5.79
3	3.500	.216	7.58
3-1/2	4.000	.226	9.11
4	4.500	.237	10.79
5	5.563	.244	13.70
6	6.625	.250	17.02
8	8.625	.250	22.36
10	10.750	.250	28.04
*12	12.750	.312	41.45
*14	14.000	.312	45.68
*16	16.000	.312	52.27
*18	18.000	.375	70.59
*20	20.000	.375	78.60

* Note: Steel casing installed in a well greater than a nominal diameter of ten (10) inches, having a wall thickness of .250 inch and meeting ASTM A-53 A or B specifications must not exceed the following depth limitations (Diameter - Maximum Depth, respectively):

1. 12 inches - 500 feet
2. 14 - 16 inches - 250 feet
3. 18 - 20 inches - 100 feet