

Figure: 25 TAC §265.172(f)(2)

Fixture Schedule	Females	Males
Water Closets	1/50	1/100 ¹
Urinals	NA	1/100 ¹
Lavatories	1/150	1/150
Cleansing showers ²	1/100	1/100
Baby Changing Table	1 per sanitary facility	1 per sanitary facility

¹Where urinals are provided, one water closet less than the number specified may be provided for each urinal installed except the number of water closets shall not be reduced to less than one-half of the minimum specified.

²Where tower rinsing showers are provided at the entry or exit into the lagoon, one shower less than the number specified may be provided for each tower rinsing shower except the number of conventional showers shall not be reduced to less than one-half of the minimum specified. Tower rinsing showers are not required to provide heated water.