

Figure: 25 TAC §265.172(g)(2)

Fixture Schedule	Females	Males
Water Closets	1/50	1/100 ¹
Urinals	NA	1/100 ¹
Lavatories ²	1/150	1/150
Rinsing showers ³	1/200	1/200
Baby Changing Table	1 per sanitary facility	1 per sanitary facility

¹ Where urinals are provided, one water closet less than the number specified may be provided for each urinal installed except the number of water closets shall not be reduced to less than one-half of the minimum specified.

² Lavatories shall be provided with hot and cold running water.

³Rinsing showers can be tower showers or single showers without heated water, or individual showers with hot and cold running water.