

Figure: 26 TAC §554.340(3)(C)(xi)

Area Designation	Air Movement In Relation To Adjacent Area	Minimum Total Air Changes Per Hour	All Air Exhausted To Outside	Design Temperature
Resident Room	--	2	--	75/78
Examination and Treatment Room	--	4	No	75/78
Physical Therapy	In	4	No	75/78
Occupational Therapy	--	4	No	75/78
Soiled Work or Holding Room	In	6	Yes	--
Clean Work or Holding Room	Out	4	No	--
Toilet Rooms	In	10	Yes	--
Bath and Shower Rooms	--	10	No	75/78
Janitors' Closets	In	10	Yes	--