

Figure: 25 TAC §265.306(c)

Disinfectant and Cyanuric Acid Levels	Minimum	Ideal	Maximum
Free Available Chlorine	1.0 ppm	3.0 - 5.0 ppm	8.0 ppm
Bromine	2.5 ppm	5.5 - 7.5 ppm	12.0 ppm
Combined Chlorine: Out-of-Door Facilities Only	0.0 ppm	0.0 ppm	1.5 ppm
Combined Chlorine: Indoor Facilities Only	0.0 ppm	0.0 ppm	0.5 ppm
Cyanuric Acid (Stabilizer) - Out-of-Door Facilities Only	0.0 ppm	20 ppm	50 ppm
Cyanuric Acid (Stabilizer) - Indoor Facilities	0.0 ppm	0.0 ppm	0.0 ppm