

Figure: 25 TAC §134.131(f)

TABLE (6)

**STATION OUTLETS FOR OXYGEN, VACUUM, AND MEDICAL AIR SYSTEMS**

<b>Location</b>	<b>Number of Outlets*</b>	
	<b>Oxygen</b>	<b>Vacuum</b>
<b>Patient rooms</b>	<b>1</b>	<b>1</b>
<b>Examination/Treatment rooms</b>	<b>1</b>	<b>1</b>
<b>Isolation room</b>	<b>1</b>	<b>1</b>
<b>Emergency care secure holding area</b>	<b>1</b>	<b>1</b>
<b>Emergency care exam/treatment room</b>	<b>1</b>	<b>1</b>

\* Number of outlets indicated is required per each bed location or treatment unit.