

Figure: 30 TAC §290.45(d)(1)

Table A

Type of Establishment	Gallons/Person/Day
Restaurants.	18
.....	
Schools without cafeterias, gymnasiums, or showers. . . .	18
.....	
Schools with cafeterias, but no gymnasiums or showers.	24
.....	
Schools with cafeterias, gymnasiums, and showers.	30
.....	
Youth camps without flush toilets, showers, or dining halls.	6
Youth camps with flush toilets, but no showers or dining halls. . .	24
Youth camps with flush toilets, showers, and dining halls.	42
Office buildings.	18
.....	
Hospitals (based on number of beds).	720
.....	
Institutions, other than hospitals.	240
.....	
Factories (exclusive of industrial processes).	24
.....	
Parks.	6
.....	
Swimming pools.	12
.....	
Country clubs.	120
.....	
Airports (per passenger).	6
.....	
Self-service laundries.	60
.....	
Service stations/stores.	12
.....	

It should be noted that this table is used to determine minimum capacities only and that the overriding criteria will be the ability of the system to maintain a minimum pressure of 35 psi under normal operating conditions. Minimum distribution pressure shall not be less than 20 psi at any time.