

Table II. Adjusted Organic Strength

<p>Sewage sources entering a graywater reuse system or a combined reuse system</p>	<p>Five-day Biochemical Oxygen Demand (BOD₅) design strength for sewage entering on-site sewage facilities milligrams per liter (mg/l)</p>
<p>Clothes-washing machine only</p>	<p>375</p>
<p>Showers, bathtubs, hand-washing lavatories, and sinks that are not used for the disposal of hazardous or toxic ingredients</p>	<p>430</p>
<p>Clothes-washing machines, showers, bathtubs, hand-washing lavatories, and sinks that are not used for the disposal of hazardous or toxic ingredients</p>	<p>600</p>