

Figure: 16 TAC §13.93(g)(e)

13.93 SIGNS/LETTERING

Requirements	Automatic Dispenser/ Refueling Area ⁵	Fueling Connection Receptable CNG Fueled Vehicle	Engine Compartment of CNG Fueled Vehicle	Emergency Shutdown Devices	Compression Area ⁵
1. Signs with Red Letters at Least 2 Inches High, on White Background - NO SMOKING ¹	#				#
2. Sign with Red Letters at Least 4 Inches High, on White Background: WARNING- FLAMMABLE GAS; Black letters: NO TRESPASSING					#
3. Letters at Least 2 Inches High: NATURAL GAS	# ⁷				#
4. CNG FUELED VEHICLE		# ²	#		
5. System Working Pressure _____		# ²	#		
6. Name of Licensee and License Number			#		
7. Cylinder Retest Date(s) or Expiration Date(s) ³		# ²	#		
8. Total Cylinder Water Volume in Gallons			#		
9. Sign with White Letters at Least 2 Inches High on Red Background: CNG EMERGENCY VALVE; PUSH				# ⁴	
10. Letters at Least 4 Inches High: Name of Licensee Operating Installation	# ⁶				# ⁶

NOTES TO '13.93, TABLE 1

1. *Location of sign shall be determined by on-site conditions, but shall be visible from each point of transfer.*
2. *On durable label, readily visible. Information in items 4, 5, 6, 7, 8 may be combined on one label.*
3. *When applicable.*
4. *Devices shall be distinctly marked for easy recognition with permanently affixed, legible sign.*
5. *Does not apply to residential/refueling facility.*
6. *One sign may be installed at either location.*
7. *On each operating side of dispenser.*