

Figure: 16 TAC §13.203

<b>NFPA 52 Sections with Additional Requirements or Not Adopted</b>		
<b>Affected NFPA 52 Section</b>	<b>Specific Action</b>	<b>Commission Rule(s) to be Followed or Other Comments</b>
1.4.1	additional requirement	See Commission rule §13.37, Appurtenances and equipment
1.4.1.2	additional requirement	See Commission rule §13.37, Appurtenances and equipment
1.4.3	additional requirements	See Commission rule §13.70, Examination and exempt registration requirements and renewals and §13.72, Designation and responsibilities of company representatives <b>and [an]</b> operations supervisors
4.2	additional requirements	See Commission rule §13.70, Examination and exempt registration requirements and renewals and §13.72, Designation and responsibilities of company representatives <b>and [an]</b> operations supervisors
4.3	additional requirement	See Commission rule §13.35, Application for an exception to a safety rule
5.2.1.1	additional requirement	See Commission rule §13.22, Odorization
5.3.1	additional requirement	See Commission rule §13.37, Appurtenances and equipment
5.4.5.1	additional requirement	See Commission rule §13.40, Manufacturer's nameplate and markings on ASME containers
6.3.2	additional requirement	See Commission rule §13.133, Installation of fuel supply containers
6.3.3	additional requirement	See Commission rule §13.133, Installation of fuel supply containers
6.9.3	additional requirement	See Commission rule §13.34, Vehicle fueling connection
6.13.2	additional requirement	See Commission rule §13.23, Installation and maintenance
6.14.1.1	additional requirement	See Commission rule §13.143, Venting of CNG to the atmosphere
7.3.1	additional requirement	See Commission rule §13.25, Filings required for stationary CNG installations
7.3.2	additional requirements	See Commission rule §13.93, System protection requirements
7.4.3.11	additional requirement	See Commission rule §13.93, System protection requirements
7.11.5.2	additional requirement	See Commission rule §13.93, System protection requirements

7.14.4	additional requirement	See Commission rule §13.107, Dispenser installation
7.14.5	additional requirement	See Commission rule §13.107, Dispenser installation
7.14.12	additional requirement	See Commission rule §13.93, System protection requirements
7.16.2	not adopted	See Commission rule §13.107, Dispenser installations
8.2.1	additional requirement	See Commission rule §13.183, System component qualifications
8.5	additional requirement	See Commission rule §13.187, Installation of pressure relief devices
8.8.3	not adopted	See Commission rule §13.190, Piping and hose
Chapter 9	not adopted	NFPA 52 Chapter 9 does not apply to CNG installations
Chapter 10	not adopted	NFPA 52 Chapter 10 does not apply to CNG installations
Chapter 12	not adopted	NFPA 52 Chapter 12 does not apply to CNG installations
Chapter 13	not adopted	NFPA 52 Chapter 13 does not apply to CNG installations
Chapter 14	not adopted	Commission rules in Chapter 13 do not cover marine installations