

Figure: 30 TAC §290.110(c)(1)(B)(i)

Entry Point Disinfectant Residual Monitoring Frequency for  
Grab Samples

<b>System Size by Population</b>	<b>Samples/day</b>
500	1
501 to 1,000	2
1,001 to 2,500	3
2,501 to 3,300	4