

Figure: 30 TAC §290.110(f)(6)

$$V = \frac{b \times 100}{a}$$

Where:

- a = number of instances where the residual disinfectant concentration is measured during the month;
- b = number of instances during the month where the residual disinfectant concentration is measured but is detected at less than 0.2 mg/L free chlorine or less than 0.5 mg/L chloramine.