

Figure: 30 TAC §117.1310(a)(1)(D)(ii)



Where:

E_{avg} = system-wide heat input weighted average NO_X emission rate, lb/MMBtu;

E_i = hourly average NO_X emission rate for utility boiler i , lb/MMBtu;

i = each utility boiler in the system;

N = the total number of utility boilers in the system; and

H_i = hourly average heat input for utility boiler i , MMBtu/hr.