

Figure: 30 TAC §217.182(g)(3)

Table G.2 - Trickling Filter Dosing Intensity Ranges (SK)

BOD₅ loading kilogram (kg)/m³/day	Design SK mm/pass	Flushing SK mm/pass
0.25	10-100	≥200
0.50	15-150	≥200
1.00	30-200	≥300
2.00	40-250	≥400
3.00	60-300	≥600
4.00	80-400	≥800