

Maximum Contaminant Levels (MCLs).

Values obtained from 40 CFR Part 141, Subparts B and G, Maximum Contaminant Levels and 40 CFR Part 143, Total Dissolved Solids.

Constituent	MCL (mg/l)
Arsenic	0.05
Barium	1
*Benzene	0.005
Cadmium	0.005
*Carbon tetrachloride	0.005
Chlordane	0.002
*Chlorobenzene	0.1
Chromium	0.1
2,4-D	0.07
*Dibromochloropropane	0.0002
*ortho-Dichlorobenzene	0.6
*para-Dichlorobenzene	0.075
*1,2-Dichloroethane	0.005
*1,1-Dichloroethylene	0.007
*trans-1,2-Dichloroethylene	0.1
*1,2-Dichloropropane	0.005
*Ethylbenzene	0.7
Heptachlor	.0004
Heptachlor epoxide	0.0002
Lead	0.05
Mercury	0.002
Methoxychlor	0.04
Pentachlorophenol	0.001
Selenium	0.05
Silver	0.05
*Styrene	0.1
*Tetrachloroethylene	0.005
*1,1,1-Trichloroethane	0.20
*Trichloroethylene	0.005
*Toluene	1
Toxaphene	0.003
2,4,5-TP (Silvex)	0.05
*Vinyl chloride	0.002
*Xylenes (total)	10
Total Dissolved Solids	500

\* For a class 3 waste classification, these constituents must also be evaluated using the test methods described in 40 Code of Federal Regulations Part 261, Appendix II. See 335.507(4)(A)(ii) for additional information.